


TWR-19248



Teledyne TABER 206-1000 and 2210-3000 Pressure Transducer Proof Test and Burst Test Final Test Report

May 1989

Prepared for

**National Aeronautics and Space Administration
George C. Marshall Space Flight Center
Marshall Space Flight Center, Alabama 35812**

Contract No. NASA-3400
DR No. 5-3
WBS No. HQ802-0550
EC3 No. SS-280

MORTON THIOKOL, INC.

Aerospace Group

Space Operations

P.O. Box 707, Brigham City, Utah 84302-0707 (801) 863-3611

Publication No. 89734

(NASA-CR-183672) TELEDYNE TABER 206-1000
AND 2210-3000 PRESSURE TRANSDUCER PROOF TEST
AND BURST TEST Final Test Report (Morton
Thiokol) 51 p

N89-24594

CSCL 14B

Unclass

G3/35 0218047

MORTON THIOKOL, INC.

Space Operations

TWR-19248

Teledyne Taber 206-1000 and 2210-3000 Pressure Transducer
Proof Test and Burst Test Final Test Report

Prepared by:

D. A. Rieh for Diane Garecht
Test Planning and Reporting
Systems Engineer

Approved by:

D. A. Rieh for
Test Planning and Reporting
Supervisor

Kel Clark
Program Manager

P.C. Lydeck 5-5-89
Data Management/Release
ECS No. 2801

JF Rittenhouse
Project Engineer

Stephen H. West
Reliability

Philip C. Greenhalgh
System Safety

CONTENTS

<u>Section</u>		<u>Page</u>
1	INTRODUCTION	1
	1.1 TEST ITEM DESCRIPTION	1
2	TEST OBJECTIVES	2
3	SUMMARY, CONCLUSIONS, AND RECOMMENDATION	3
	3.1 SUMMARY	3
	3.2 CONCLUSIONS	3
	3.3 RECOMMENDATION	4
4	INSTRUMENTATION	5
5	PHOTOGRAPHY	6
6	TEST RESULTS AND DISCUSSION	7
	6.1 RANDOM VIBRATION TEST	7
	6.1.1 Introduction	7
	6.1.2 Objective	7
	6.1.3 Results and Discussion	7
	6.2 PRESSURE CALIBRATION	8
	6.2.1 Introduction	8
	6.2.2 Objective	8
	6.2.3 Results and Discussion	8
	6.3 150-PERCENT MAXIMUM PRESSURE TEST	9
	6.3.1 Introduction	9
	6.3.2 Objectives	9
	6.3.3 Results and Discussion	9
	6.4 BURST TEST	9
	6.4.1 Introduction	9
	6.4.2 Objectives	9
	6.4.3 Results and Discussion	14
7	APPLICABLE DOCUMENTS	19

APPENDIXES

<u>Appendix</u>	<u>Page</u>
A Pressure Calibration After Vibration Test	A-1
B Pressure Calibration.	B-1
C Calibration After Maximum Pressure Test	C-1

FIGURES

<u>Figure</u>		<u>Page</u>
1	150-Percent Pressure Transducer Proof Test (Model 206--S/N 870222)	10
2	150-Percent Pressure Transducer Proof Test (Model 206--S/N 848504)	11
3	150-Percent Pressure Transducer Proof Test (Model 2210--S/N 842258)	12
4	150-Percent Pressure Transducer Proof Test (Model 2210--S/N 882181)	13
5	Burst Pressure (Model 206--870222)	15
6	Burst Pressure (Model 206--848504)	16
7	Burst Pressure (Model 2210--842258)	17
8	Burst Pressure (Model 2210--882181)	18

INTRODUCTION

The purpose of this test was to verify the range accuracy and structural integrity of the Teledyne Taber 206-1000 and 2210-3000 pressure transducers and to determine if multiple uses have a significant effect on the transducers. Burst pressure for these transducers was also established.

The Teledyne Taber Model 206-1000 pressure transducer is used to measure chamber pressure on full-scale space shuttle solid rocket motors. The Teledyne Taber Model 2210-3000 pressure transducer is used to measure igniter pressure. The Teledyne Taber transducer has very good temperature stability and has been used on all full-scale solid rocket motors, so there is a large data base established using this transducer.

1.1 TEST ITEM DESCRIPTION

Two Teledyne Taber 206-1000 transducers and two 2210-3000 transducers were subjected to all phases of the tests. One transducer of each model number was unused, and the other had multiple uses.

The burst test was conducted in a metal bursting box using a deadweight tester. The vibration test took place at the Morton Thiokol, Inc. vibration facility (T-53). All other testing took place at M-9.

The test item configuration was controlled by WTP-0185 and the applicable documents referenced in that document.

TEST OBJECTIVES

The developmental objectives for this test are as follows:

1. Verify that the measurement of the Teledyne Taber 206-1000 and 2210-3000 pressure transducers will be accurate to ± 2 percent of full scale.
2. Determine whether repeated uses degrade the performance of the transducers.
3. Verify that pressure calibration remains constant following vibration loading specified in this test plan.
4. Determine if the Teledyne Taber 206-1000 and 2210-3000 remain operational following 150 percent of the maximum operational pressure.
5. Determine transducer bursting pressure at ambient temperature.

SUMMARY, CONCLUSIONS, AND RECOMMENDATION

3.1 SUMMARY

Two 206-1000 transducers and two 2210-3000 transducers were subjected to all phases of the tests. One transducer of each model number was new and the other had multiple uses.

All transducers were vibrated in two axis directions for 7g root mean square for 6 min. The 206-1000 transducer was pressurized to 1,000 +50/-0 psig and the 2210-3000 transducer was pressurized to 3,000 ±100 psig during the vibration test.

An 11-point pressure transducer calibration procedure was then completed five times for each transducer. The pressure transducer voltage output was recorded to ±0.0001 V.

The 150-percent maximum pressure test was run; all transducers were functional during and after the test.

A burst test was then conducted at ambient temperature to verify the structural integrity and to determine the burst strength of the Teledyne Taber transducers. The 206-1000 transducers were pressurized to 1,500 psig and the 2210-3000 transducer to 4,500 psig.

3.2 CONCLUSIONS

The following is a one-on-one correlation of development objectives with test results. Detailed results can be found in the sections referenced in parenthesis.

<u>Objective</u>	<u>Results</u>
1. Verify that the measurement of the Teledyne Taber 206-1000 and 2210-3000 pressure transducers will be accurate to ±2 percent of full scale.	The measurements of the 206-1000 and 2210-3000 were accurate to ±2 percent full scale. (6.2)

Objective

2. Determine whether repeated uses degrade the performance of the transducers.
3. Verify that pressure calibration remains constant following vibration loading specified in this test plan.
4. Determine if the Teledyne Taber 206-1000 and 2210-3000 remain operational following 150 percent of the maximum operational pressure.
5. Determine transducer bursting pressure at ambient temperature.

Results

Repeated uses do not degrade the performance of the transducers. (6.3, 6.4)

Pressure calibration remained constant after vibration loading. (6.1)

All transducers remained operational following 150-percent maximum pressure test. (6.3)

Determined--See table in Section 6.4.3 for specific values.

3.3 RECOMMENDATION

Burst Test

Cap screw torque on all 206-1000 transducers should be checked in subsequent tests.

INSTRUMENTATION

Standard laboratory equipment traceable to NBS was used to support this test. All instrumentation was calibrated in accordance with MIL-STD-45662. All instruments were calibrated and recorded before and after each test. Lab standards were used during pressure calibration tests.

5

PHOTOGRAPHY

Prior to testing, still color photographs were taken of the test item assembly and typical instrumentation. Post-test photographs were required for test documentation.

REVISION _____

DOC NO. TWR-19248
SEC PAGE VOL
6

TEST RESULTS AND DISCUSSION

6.1 RANDOM VIBRATION TEST

6.1.1 Introduction

A random vibration test was performed at T-53 to verify the structural integrity of the Teledyne Taber 206-1000 and 2210-3000 pressure transducers. For the random vibration test, the 206-1000 transducer was assembled to the 1U50731-09 configuration, and the 2210-3000 transducer was assembled to the 1U50731-12 configuration.

Each transducer was subjected to random vibration at 7g root mean square for 6 min following the vibration criteria listed below (refer to SE-019-049-2H). The 206-1000 transducer was pressurized to 1,000 +50/-0 psig and the 2210-3000 transducer was pressurized to 3,000 ±100 psig during the vibration test.

20 - 50 Hz at 0.020 g²/Hz
50 - 150 Hz at +3 dB/oct
150 - 500 Hz at 0.060 g²/Hz
500 - 2,000 Hz at -6 dB/oct
2,000 Hz at 0.0038 g²/Hz

The test was performed in the two axis directions (longitudinal and lateral).

Vibration was recorded and verified by T-53 personnel to be within the criteria listed above.

6.1.2 Objective

The vibration test was run to support the following test objective:

Verify that pressure calibration remains constant following vibration loading specified in this test plan.

6.1.3 Results and Discussion

The vibration test verified the structural integrity of the Teledyne Taber transducers. The 206-1000 transducer maintained a pressure of 1,000 psi and

the 2210-3000 transducer maintained a pressure of 3,000 psi during vibration loading with no visible leakage occurring.

The gage was verified to be functional following this test during the 150-percent overpressure test documented in Section 6.3 of this report. Pressure calibration change was negligible after the vibration test (Appendix A).

6.2 PRESSURE CALIBRATION

6.2.1 Introduction

An 11-point pressure transducer calibration procedure was completed five times for each transducer. The pressure transducer voltage output was recorded to ± 0.0001 V.

1. Ten Vdc were applied to input of pressure transducer. Pressure transducer voltage output and lab standard pressure were recorded. This was performed before and after 150-percent maximum pressure test.
2. Pressure was increased from 0 to 1,000 psig for the 206-1000 transducer and from 0 to 3,000 psig for the 2210-3000 transducer in 200-psi increments. Lab standard pressure and pressure transducer voltage output were recorded at each 200-psi increment.
3. Pressure was decreased back to 0 psig in 200-psi increments. Lab standard pressure and pressure transducer voltage output was recorded at each 200-psi increment.

6.2.2 Objective

The pressure calibration was run to support the following test objective:

Verify the measurement of the Teledyne Taber 206-1000 and 2210-3000 pressure transducers will be accurate to ± 2 percent of full scale.

6.2.3 Results and Discussion

The Teledyne Taber 206-1000 and 2210-3000 pressure transducers were verified to be accurate to ± 2 percent full scale (Appendix B).

6.3 150-PERCENT MAXIMUM PRESSURE TEST

6.3.1 Introduction

Ten-Vdc input was applied to each pressure transducer. Pressure was increased to 1,500 psig for the 206-1000 transducer and 4,500 psig for the 2210-3000 transducer. Pressure transducer voltage output versus time and lab standard pressure versus time were recorded. The pressure calibration test, as outlined in Section 6.2.1, was repeated.

6.3.2 Objectives

The 150-percent maximum pressure test was run to support the following test objectives:

Determine whether repeated uses degrade the performance of the transducers.

Determine if the Teledyne Taber 206-1000 and 2210-3000 remain operational following 150 percent of the maximum operational pressure.

6.3.3 Results and Discussion

All transducers remained functional for the duration of the test; the reading returned to zero following the test (Figures 1 through 4). No leakage was noted. The transducers were recalibrated after the maximum pressure test; the change was negligible (Appendix C).

6.4 BURST TEST

6.4.1 Introduction

All transducers were subjected to this test. A burst test was conducted at ambient temperature to verify the structural integrity and to determine the burst strength of the Teledyne Taber transducers. The transducers were installed in the metal bursting box. The 206-1000 transducers were pressurized to 1,500 psig and the 2210-3000 transducers to 4,500 psig. Pressure was increased in 500-psi increments until burst occurred.

6.4.2 Objectives

The burst tests were performed to support the following objectives:

MORTON THIOKOL INC.

Space Operations




Figure 1. 150-Percent Pressure Transducer Proof Test (Model 206—S/N 870222)

MORTON THIOKOL, INC.

Space Operations




Figure 2. 150-Percent Pressure Transducer Proof Test (Model 206—S/N 848504)

MORTON THIOKOL, INC.

Space Operations




Figure 3. 150-Percent Pressure Transducer Proof Test (Model 2210—S/N 842258)

MORTON THIOKOL, INC.

Space Operations




Figure 4. 150-Percent Pressure Transducer Proof Test (Model 2210—S/N 882181)

Determine whether repeated uses degrade the performance of the transducers.

Determine transducer bursting pressure at ambient temperature.

6.4.3 Results and Discussion

The burst pressure traces are shown in Figures 5 through 8. Repeated uses do not degrade the performance of the transducers, as shown by the bursting pressures. Burst test results are listed in the table below.

Burst Test Results

<u>Model No.</u>	<u>S/N</u>	<u>Pressure Rating (psi)</u>	<u>Previous Uses</u>	<u>Burst Pressure (psi)</u>
206-1000	870222	1,000	Multiple	11,259
206-1000	848504	1,000	None	10,577
2210-3000	842258	3,000	Multiple	18,055
2210-3000	882181	3,000	None	18,088

The failure modes are listed below.

2210-3000--The diaphragm ruptured, followed by the electrical connector being blown out of the case.

206-1000--A leak developed between the diaphragm cap and the transducer body joint. No damage was apparent after disassembly.




Figure 5. Burst Pressure (Model 206—S/N 870222)




Figure 6. Burst Pressure (Model 206—S/N 848504)




Figure 7. Burst Pressure (Model 2210—S/N 842258)




Figure 8. Burst Pressure (Model 2210-S/N 882181)

APPLICABLE DOCUMENTS

- | | |
|---------------|---|
| WTP-0185 | Teledyne Taber 206-1000 and 2210-3000 Pressure Transducer Proof Test and Burst Test Final Test Report |
| MIL-STD-45662 | Calibration Systems Requirements |
| SE-019-049-2H | Solid Rocket Booster Vibration, Acoustic and Shock Design and Test Criteria |
| 1U50731 | Transducer Bolt Assembly |

MORTON THIOKOL, INC.

Space Operations

Appendix A

Pressure Calibration After Vibration Test

TRANSDUCER CALIBRATION WORKSHEET

ASCENDING

ORIGINAL PAGE IS
OF POOR QUALITY

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
TABER	2210	882181	3000	1		
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT			
	15 FEB 89	10.00 VDC	16856	2		
BAROMETER	MEGOMHMS TO GROUND	BATTERY	STANDARD			
			24930	3		
LOADING TECH.	RECORDING TECH.	COMPUTING TECH.	READ OUT			
16783	16783			4		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V					
<input checked="" type="checkbox"/> RECEIVING RESP.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR	6		
APPLIED LOAD	PSI	MV OUTPUT		AVERAGE	% OF F.S.	LIN
Z OUT	Input	Run 1	Run 2	Run 3	Run 4	Run 5
-10	0	0000	0000	0000	0000	
-20	200	2.008	2.006	2.009	2.010	2.010
-40	400	4.018	4.017	4.017	4.019	4.018
-60	600	6.028	6.026	6.025	6.030	6.027
-75	800	8.035	8.034	8.034	8.037	8.030
-100	1000	10.038	10.039	10.038	10.041	10.042
-80	1200	12.043	12.039	12.045	12.043	12.046
-60	1400	14.050	14.047	14.045	14.050	14.046
-40	1600	16.051	16.048	16.047	16.047	16.047
-20	1800	18.030	18.043	18.043	18.050	18.038
0	2000	20.035	20.040	20.041	20.044	20.039
-20	2200	22.026	22.030	22.028	22.030	22.034
-40	2400	23.960	24.013	24.018	24.021	24.018
-60	2600	26.024	26.018	26.012	26.005	26.004
-80	2800	27.987	27.997	27.993	27.991	28.004
-100	3000	29.984	29.978	29.991	29.983	29.980
-80						
-60						
-40						
-20						
-0						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

DESCENDING

MANUFACTURER TABER	MODEL 2210	SERIAL NO. 882181	RANGE 3000	STEPS 1	SHUNTS	% OF F.S.
CHANNEL	CALIBRATION DATE 15 FEB 89	EXCITATION 10.00 VDC	LOADING INSTRUMENT 16856	2		
BAROMETER	MEGOMHS TO GROUND	BATTERY	STANDARD 24930	3		
LOADING TECH. 16783	RECORDING TECH. 16783	COMPUTING TECH.	READ OUT	4		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY MV/V	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	SHUNT MODULE MV/V	TENSION F.S.	CONVERSION FACTOR	6		
<input type="checkbox"/> RECEIVING INSPI.						
APPLIED LOAD %	PST	MV OUTPUT		AVERAGE	% OF F.S.	LIN HYS
Z OUT	input	Run 1	Run 2	Run 3	Run 4	Run 5
0	3000	29.984	29.979	29.991	29.983	29.980
20	2800	28.027	27.996	28.005	27.995	28.002
40	2600	26.032	26.025	26.024	26.022	26.024
60	2400	23.973	24.030	24.037	24.029	24.031
80	2200	22.043	22.046	22.047	22.045	22.037
100	2000	20.043	20.053	20.053	20.050	20.054
80	1800	18.052	18.059	18.056	18.061	18.054
60	1600	16.058	16.059	16.059	16.062	16.059
40	1400	14.043	14.061	14.058	14.062	14.059
20	1200	12.054	12.056	12.055	12.060	12.055
0	1000	10.053	10.052	10.051	10.057	10.053
-20	800	8.047	8.046	8.046	8.049	8.047
-40	600	6.040	6.036	6.037	6.041	6.037
-60	400	4.029	4.027	4.028	4.029	4.026
-80	200	2.018	2.014	2.104	2.016	2.013
-100	0	.0000	.0000	.0000	.0003	.0001
-80						
-60						
-40						
-20						
-0						
Z OUT						

ORIGINAL PAGE IS
OF POOR QUALITY

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER
 MODEL#: 206
 SERIAL#: 848504
 RANGE: 1000 PSIG
 DATE: 16 FEB 89
 SL#: N/A
 READOUT: 24930
 POS: 9.9994 V.DC
 REF STD ID# 16856
 SHUNTS: 3 MV/V
 TNS RES: 10K MEG OHMS
 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
 ZERO= 0.000 0.000
 #1 = 7.528 7.528 25.08 25.01
 #2 = 15.055 15.055 50.15 50.06
 #3 = 22.581 22.581 75.22 75.15
 #4 = 30.103 30.103 100.28 100.27
 TEMP. DEG.F = 75
 EXCITATION = 9.9994 V.DC
 SENSITIVITY = 3.002 MV/V
 POT OUT = 0.2720 MV
 CONVERSION FACTOR = 3.33133453

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.001	0.000	0.000	0.000	0.00	
20% =	6.012	6.016	6.015	6.014	6.014	20.03
40% =	12.030	12.034	12.031	12.032	12.031	40.08
60% =	18.039	18.041	18.047	18.042	18.042	60.10
80% =	24.042	24.040	24.039	24.040	24.040	80.09
100% =	30.025	30.023	30.007	30.018	30.018	100.00
80% =	24.069	24.060	24.061	24.063	24.063	80.16 0.07
60% =	18.059	18.051	18.060	18.057	18.056	60.15 0.05
40% =	12.041	12.043	12.045	12.043	12.043	40.12 0.04
20% =	6.018	6.019	6.017	6.018	6.018	20.05 0.02
0% =	0.000	0.001	-0.002	0.000	-0.001	0.00 0.00

$$Y=A+BX+CX^2 \quad A=-3.858E-03 \quad B=.301404 \quad C= -1.149E-05$$

RR= .999999838



CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	848504 SERIAL #	16 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	9.9994 EXCITATION V.DC.	3.002 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL SIMULATION	LINEARITY	HYSTERESIS
#1 = 25.01	100% = 100.00	80% = 0.07
#2 = 50.06	80% = 80.09	60% = 0.05
#3 = 75.15	60% = 60.10	40% = 0.04
#4 = 100.27	40% = 40.08	20% = 0.02
	20% = 20.03	0% = 0.00

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER
 MODEL#: 206
 SERIAL#: 848504
 RANGE: 1000 PSIG
 DATE: 16 FEB 89
 SL#: N/A
 READOUT: 24930
 MODE: POS
 REF. STD: 16856
 SHUNTS: 3 MV/V
 INS. RES. >10K MEG OHMS

3 MV/V SHUNTS	-ZERO	%F.S.	SH/LIN
ZERO=	0.000	0.000	
#1 =	7.526	7.526	25.08
#2 =	15.053	15.053	50.16
#3 =	22.578	22.578	75.23
#4 =	30.102	30.102	100.31
TEMP. DEG.F =	75		
EXCITATION =	9.9992 V.DC		
SENSITIVITY =	3.001 MV/V		
POT OUT =	0.2770 MV		
CONVERSION FACTOR =	3.33218558		

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.001	0.000	0.000	0.000	0.00	
20% =	6.011	6.014	6.016	6.014	6.013	20.04	
40% =	12.029	12.028	12.026	12.028	12.027	40.08	
60% =	18.034	18.029	18.037	18.033	18.033	60.09	
80% =	24.035	24.043	24.042	24.040	24.040	80.10	
100% =	29.998	30.017	30.017	30.011	30.010	100.00	
80% =	24.055	24.061	24.055	24.057	24.057	80.16	0.06
60% =	18.057	18.060	18.054	18.057	18.057	60.17	0.08
40% =	12.039	12.036	12.036	12.037	12.037	40.11	0.03
20% =	6.018	6.015	6.019	6.017	6.017	20.05	0.01
0% =	0.000	-0.002	0.001	0.000	-0.001	0.00	0.00

$$Y=A+BX+CX^2 \quad A=-3.572E-03 \quad B=.301278 \quad C= -1.084E-05$$

RR= .999999714



CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	848504 SERIAL #	16 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	POS EXCITATION V.DC.	3.001 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL SIMULATION	LINEARITY	HYSERESIS
#1 = 25.01	100% = 100.00	80% = 0.06
#2 = 50.07	80% = 80.10	60% = 0.08
#3 = 75.16	60% = 60.09	40% = 0.03
#4 = 100.29	40% = 40.08	20% = 0.01
	20% = 20.04	0% = 0.00

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER
 MODEL#: 206
 SERIAL#: 870222
 RANGE: 1000 PSIG
 DATE: 16 FEB 89
 SL#: N/A
 READOUT: 24412
 MODE: POS
 REF. STD: 16856
 SHUNTS: 3 MV/V
 INS. RES. >10K MEG OHMS

3 MV/V SHUNTS	-ZERO	%F.S.	SH/LIN
ZERO= 0.000	0.000		
#1 = 7.513	7.513	25.04	25.02
#2 = 15.024	15.024	50.08	50.04
#3 = 22.536	22.536	75.12	75.09
#4 = 30.049	30.049	100.16	100.15
TEMP. DEG.F = 75			
EXCITATION = 10.0015 V.DC			
SENSITIVITY = 3.000 MV/V			
POT OUT = 0.3260 MV			
CONVERSION FACTOR = 3.33333333			

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.000	0.000	0.000	0.000	0.00	
20% =	6.002	6.003	6.003	6.003	6.003	20.01	
40% =	12.007	12.007	12.009	12.008	12.008	40.03	
60% =	18.011	18.008	18.014	18.011	18.011	60.04	
80% =	24.011	24.021	24.017	24.016	24.016	80.05	
100% =	29.996	29.997	30.007	30.000	30.000	100.00	
80% =	24.030	24.032	24.028	24.030	24.030	80.10	0.05
60% =	18.026	18.031	18.030	18.029	18.029	60.10	0.06
40% =	12.014	12.015	12.014	12.014	12.014	40.05	0.02
20% =	6.002	6.004	6.005	6.004	6.004	20.01	0.00
0% =	-0.002	0.000	-0.002	-0.001	-0.001	0.00	0.00

$$Y=A+BX+CX^2 \quad A=-2.465E-03 \quad B=.300481 \quad C= -4.19E-06$$

RR= .999999865



CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	870222 SERIAL #	16 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	POS EXCITATION V.DC.	3.000 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL	LINEARITY	HYSERESIS
SIMULATION	100% = 100.00	80% = 0.05
#1 = 25.02	80% = 80.05	60% = 0.06
#2 = 50.04	60% = 60.04	40% = 0.02
#3 = 75.09	40% = 40.03	20% = 0.00
#4 = 100.15	20% = 20.01	0% = 0.00

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER
 MODEL#: 206
 SERIAL#: 870222
 RANGE: 1000 PSIG
 DATE: 16 FEB 89
 SL#: N/A
 READOUT: 24412
 MODE: POS
 REF ID: 776856
 SHUNTS: 3 MV/V
 INS RES: 010K MEG OHMS

3 MV/V SHUNTS	-ZERO	%F.S.	SH/LIN
ZERO=	0.000	0.000	
#1 =	7.513	7.513	25.04
#2 =	15.024	15.024	50.06
#3 =	22.538	22.538	75.10
#4 =	30.051	30.051	100.14
TEMP. DEG.F = 75			
EXCITATION = 10.0017 V.DC			
SENSITIVITY = 3.000 MV/V			
POT OUT = 0.3130 MV			
CONVERSION FACTOR = 3.33233364			

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.000	0.000	0.000	0.000	0.00	
20% =	6.003	6.006	6.005	6.005	6.005	20.01	
40% =	12.009	12.014	12.010	12.011	12.011	40.02	
60% =	18.014	18.013	18.020	18.016	18.016	60.03	
80% =	24.014	24.014	24.013	24.014	24.014	80.02	
100% =	30.007	30.017	30.003	30.009	30.009	100.00	
80% =	24.040	24.033	24.029	24.034	24.034	80.09	0.07
60% =	18.027	18.027	18.034	18.029	18.029	60.08	0.05
40% =	12.015	12.019	12.021	12.018	12.018	40.05	0.03
20% =	6.006	6.006	6.006	6.006	6.006	20.01	0.00
0% =	0.000	0.000	-0.002	-0.001	-0.001	0.00	0.00

$$Y=A+BX+CX^2 \quad A=-1.239E-03 \quad B=.300466 \quad C= -3.58E-06$$

RR= .999999981



CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	870222 SERIAL #	16 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	POS EXCITATION V.DC.	3.000 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL	LINEARITY	HYSTERESIS
SIMULATION	100% = 100.00	80% = 0.07
#1 = 25.02	80% = 80.02	60% = 0.05
#2 = 50.04	60% = 60.03	40% = 0.03
#3 = 75.08	40% = 40.02	20% = 0.00
#4 = 100.14	20% = 20.01	0% = 0.00

TRANSDUCER CALIBRATION WORKSHEET

ORIGINAL PAGE IS
OF POOR QUALITY

MANUFACTURER TABER	MODEL 2210	SERIAL NO. 842258	RANGE 3000	STEPS	SHUNTS	% OF F.S.
CHANNEL	CALIBRATION DATE 15 FEB 89	EXCITATION 10.00 VDC	LOADING INSTRUMENT 16856	2		
BAROMETER	MEGOHMS TO GROUND	BATTERY	STANDARD 24412	3		
LOADING TECH. 16783	RECORDING TECH. 16783	COMPUTING TECH.	READ OUT	4		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY MV/V	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	SHUNT MODULE MV/V	TENSION F.S.	CONVERSION FACTOR	6		
<input type="checkbox"/> RECEIVING INSPI.						
LOAD R. PSI	MV OUTPUT			AVERAGE	% OF F.S.	LIN
Z OUT	input	Run 1	Run 2	Run 3	Run 4	Run 5
-100	0000	.0000	.0000	.0000	.0000	
-80	200	2.018	2.018	2.017	2.018	2.021
-60	400	4.040	4.043	4.038	4.038	4.041
-40	600	6.061	6.062	6.058	6.060	6.061
-20	800	8.081	8.082	8.079	8.080	8.075
0	1000	10.101	10.102	10.099	10.098	10.103
20	1200	12.116	12.118	12.117	12.115	12.120
40	1400	14.134	14.132	14.130	14.135	14.131
60	1600	16.145	16.143	16.144	16.142	16.140
80	1800	18.150	18.152	18.157	18.160	18.155
100	2000	20.160	20.168	20.165	20.162	20.160
120	2200	22.170	22.170	22.168	22.167	22.167
140	2400	24.160	24.163	24.173	24.165	24.168
160	2600	26.158	26.180	26.178	26.176	26.180
180	2800	28.170	28.176	28.173	28.171	28.172
200	3000	30.170	30.180	30.178	30.172	30.180
220						
240						
260						
280						
300						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

DESCENDING

MANUFACTURER TABER	MODEL 2210	SERIAL NO. 842258	RANGE 3000	STEPS 1	SHUNTS	% OF F.S.
CHANNEL	CALIBRATION DATE 15 FEB 89	EXCITATION 10.00 VDC	LOADING INSTRUMENT 16856	2		
BAROMETER	MEGOHMS TO GROUND	BATTERY	STANDARD 24412	3		
LOADING TECH. 16783	RECORDING TECH. 16783	COMPUTING TECH.	READ OUT	4		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY MV/V	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	SHUNT MODULE MV/V	TENSION F.S.	CONVERSION FACTOR	6		
<input type="checkbox"/> RECEIVING INSPI.						
APPLIED LOAD %	PSI	MV OUTPUT		AVERAGE	% OF F.S.	LIN HYS
Z OUT	input	Run 1	Run 2	Run 3	Run 4	Run 5
0	3000	30.170	30.180	30.178	30.172	30.180
20	2800	28.142	28.185	28.180	28.176	28.180
40	2600	26.177	26.196	26.189	26.184	26.186
60	2400	24.170	24.196	24.196	24.183	24.187
80	2200	22.143	22.195	22.193	22.191	22.196
100	2000	20.113	20.190	20.188	20.190	20.189
80	1800	18.160	18.185	18.181	18.184	18.181
60	1600	16.167	16.171	16.173	16.171	16.169
40	1400	14.155	14.159	14.155	14.161	14.161
20	1200	12.136	12.143	12.141	12.146	12.142
0	1000	10.126	10.125	10.122	10.128	10.126
-20	800	8.110	8.105	8.104	8.108	8.107
-40	600	6.085	6.084	6.082	6.086	6.083
-60	400	4.062	4.062	4.060	4.063	4.060
-80	200	2.035	2.034	2.031	2.033	2.032
-100	0	.0006	.0005	.0003	.0004	.0004
-80						
-60						
-40						
-20						
-0						
Z OUT						

MORTON THIOKOL, INC.

Space Operations

**Appendix B
Pressure Calibration**

TRANSDUCER CALIBRATION WORKSHEET

ORIGINAL PAGE IS
OF POOR QUALITY

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OFF F.S.
Taber	2210	882181	0 - 3000±	1	7.526	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15.053	
AMMETER	MEGOMHMS TO GROUND	BATTERY	STANDARD	3	22.582	
ADING TECH	RECORDING TECH.	COMPUTING TECH.	READ OUT	4	30.109	
<input checked="" type="checkbox"/> TCC 16783 STD5	16783 STD5					
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V					
<input type="checkbox"/> RECEIVING IMP.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR	6		
MV/V						
APPLIED LOAD				AVERAGE	% OFF F.S.	LIN
Z OUT	Input	Run 1	Run 2	Run 3	Run 4	HYS
0	0	0.000	0.000	0.000	0.000	
20	200	2.011	2.009	2.007	2.013	2.012
40	400	4.025	4.026	4.027	4.028	4.031
60	600	6.044	6.044	6.045	6.047	6.039
80	800	8.062	8.061	8.063	8.060	8.065
100	1000	10.077	10.074	10.080	10.081	10.081
120	1200	12.092	12.089	12.096	12.089	12.093
140	1400	14.102	14.100	14.107	14.103	14.108
160	1600	16.114	16.111	16.113	16.119	16.114
180	1800	18.122	18.118	18.125	18.128	18.115
200	2000	20.128	20.126	20.128	20.130	20.129
-20	2200	22.131	22.130	22.133	22.133	22.125
-40	2400	24.133	24.129	24.131	24.136	24.125
-60	2600	26.132	26.127	26.130	26.135	26.125
-80	2800	28.133	28.129	28.127	28.132	28.125
-100	3000	30.127	30.117	30.121	30.122	30.126
-120						
-140						
-160						
-180						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

Descending

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
Taber	2210	882181	0 - 3000F	1	7.52G	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15.05J	
BAROMETER	MEGOMMS TO GROUND	BATTERY	STANDARD	3	22.58J	
LOADING TECH TCC 16783 STOS	RECORDING TECH TCC 16783 STOS	COMPUTING TECH.	READ OUT	4	30.10J	
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V					
<input type="checkbox"/> RECEIVING INSPI.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR	6		
MV/V						
APPLIED LOAD %				AVERAGE	% OF F.S.	LIN HYS
Z OUT	INPUT	Run 1	Run 2	Run 3	Run 4	Run 5
0	3000	30.127	30.117	30.121	30.122	30.126
-20	2800	28.130	28.125	28.136	28.134	28.130
-40	2600	26.128	26.132	26.145	26.147	26.140
-60	2400	24.135	24.142	24.150	24.152	24.137
-80	2200	22.140	22.138	22.153	22.146	22.135
-100	2000	20.145	20.148	20.150	20.151	20.147
-80	1800	18.155	18.146	18.146	18.148	18.152
-60	1600	16.145	16.137	16.142	16.140	16.145
-40	1400	14.134	14.124	14.133	14.130	14.135
-20	1200	12.127	12.119	12.120	12.119	12.123
0	1000	10.107	10.109	10.104	10.106	10.109
-20	800	8.096	8.089	8.092	8.088	8.092
-40	600	6.074	6.070	6.070	6.068	6.072
-60	400	4.053	4.051	4.049	4.047	4.050
-80	200	2.034	2.029	2.026	2.027	2.030
-100	0	0.007	0.002	0.003	0.001	0.004
-80						
-60						
-40						
-20						
-0						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

ORIGINAL PAGE IS
OF POOR QUALITY

Ascendus

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
Taber	2210	842258	0 - 3000 \pm	1	7.521	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15.046	
METER	MEGOMMS TO GROUND	BATTERY	STANDARD 24467 24412	3	22.567	
DAQING TECH.	TCC 16783 STD5	RECORDING TECH. TCC 16783 STD5	COMPUTING TECH.	4	30.086	
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V			6		
<input checked="" type="checkbox"/> RECEIVING THERM	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR			
APPLIED LOAD %	MV/V			AVERAGE	% OF F.S.	LIN HYS
Z OUT	Input	Run 1	Run 2	Run 3	Run 4	Run 5
0	0	0.000	0.000	0.000	0.000	
-20	200	2.001	2.000	2.005	2.003	2.005
-40	400	4.005	4.005	4.010	4.006	4.008
-60	600	6.009	6.008	6.012	6.012	6.009
-80	800	8.013	8.009	8.010	8.011	8.012
-100	1000	10.013	10.011	10.014	10.015	10.015
-80	1200	12.011	12.010	12.014	12.010	12.015
-60	1400	14.009	14.007	14.012	14.014	14.012
-40	1600	16.007	16.001	16.006	16.009	16.006
-20	1800	18.001	17.996	18.005	18.004	18.000
0	2000	19.995	19.990	19.996	19.994	19.994
-20	2200	21.983	21.984	21.983	21.981	21.978
-40	2400	23.975	23.970	23.969	23.971	23.965
-60	2600	25.953	25.948	25.950	25.955	25.945
-80	2800	27.943	27.938	27.941	27.939	27.930
-100	3000	29.920	29.912	29.918	29.920	29.917
-80						
-60						
-40						
-20						
0						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

Decending

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
Tucker	2210	842258	0 - 10000	1	7.521	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15046	
BAROMETER	MEGOMHMS TO GROUND	BATTERY	STANDARD	3	22.567	
LOADING TECH.	RECORDING TECH	COMPUTING TECH.	READ OUT	4	30.086	
TCC 16783 STDs	TCC 16783 STDs			5		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.			
<input type="checkbox"/> SINGLE SHUNT	MV/V					
<input type="checkbox"/> RECEIVING INSP.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR			
MV/V						
APPLIED LOAD %				AVERAGE	% OF F.S.	LIN HYS
Z OUT	Input	Run 1	Run 2	Run 3	Run 4	Run 5
0	3000	29.920	29.912	29.918	29.920	29.917
-20	2800	27.925	27.920	27.930	27.941	27.932
-40	2600	25.960	25.955	25.960	25.962	25.953
-60	2400	23.969	23.982	23.973	23.980	23.979
-80	2200	21.987	21.985	21.993	21.992	21.995
-100	2000	20.010	20.004	20.008	20.005	20.005
-80	1800	18.015	18.011	18.015	18.016	18.012
-60	1600	16.022	16.015	16.023	16.022	16.018
-40	1400	14.026	14.018	14.027	14.027	14.023
-20	1200	12.031	12.024	12.030	12.027	12.033
0	1000	10.026	10.028	10.029	10.029	10.031
-20	800	8.030	8.025	8.024	8.023	8.033
-40	600	6.023	6.022	6.024	6.017	6.024
-60	400	4.018	4.015	4.016	4.016	4.016
-80	200	2.009	2.009	2.008	2.007	2.011
-100	0	0.003	0.003	0.001	0.002	0.002
-80						
-60						
-40						
-20						
-0						
Z OUT						

ORIGINAL PAGE IS
OF POOR QUALITY

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
MODEL#: 206 ZERO= 0.001 0.000
SERIAL#: 848504 #1 = 7.524 7.523 25.07 25.04
RANGE: 1000 PSIG #2 = 15.049 15.048 50.15 50.09
DATE: 17 FEB 89 #3 = 22.572 22.571 75.23 75.17
SL#: N/A #4 = 30.094 30.093 100.30 100.28
READOUT: 24930 TEMP.DEG.F = 73

MODE: POS EXCITATION = 9.9965 V.DC
REF/STD: 16856 SENSITIVITY = 3.001 MV/V
SHUNTS: MV/V POT OUT = 0.3060 MV
INS.RES.>10K MEG OHMS CONVERSION FACTOR = 3.33292598

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0%	0.000	0.000	0.000	0.000	0.000	0.00	
20%	6.003	6.001	6.001	6.002	6.002	20.00	
40%	12.013	12.014	12.009	12.012	12.012	40.04	
60%	18.029	18.030	18.025	18.028	18.028	60.09	
80%	24.029	24.027	24.023	24.026	24.026	80.08	
100%	30.007	30.001	30.003	30.004	30.004	100.00	
-80%	24.043	24.042	24.051	24.045	24.045	-80.14	-0.06
60%	18.048	18.046	18.046	18.047	18.047	60.15	0.06
40%	12.035	12.032	12.028	12.032	12.032	40.10	0.06
20%	6.009	6.003	6.008	6.007	6.007	20.02	0.02
0%	0.000	-0.003	-0.002	-0.002	-0.002	-0.01	-0.01

$y = A + BX \pm CX^2$ A = -5.89299999E-03 B = .300912 C = -7.58E-06
RR = .999999567

TCC
16783
STD'S

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER 206 848504 17 FEB 89 TCC 16952 STD'S

MANUFACTURER MODEL # SERIAL # DATE/APPROVAL

1000 PSIG N/A POS 9.9965 3.001 3 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL	LINEARITY	HYSTERESIS	
SIMULATION	100% = 100.00	80% =	0.06
#1 = 25.04	80% = 80.08	60% =	0.06
#2 = 50.09	60% = 60.09	40% =	0.06
#3 = 75.17	40% = 40.04	20% =	0.02
#4 = 100.28	20% = 20.00	0% =	-0.01

ORIGINAL PAGE IS
OF POOR QUALITY

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
MODEL#: 206 ZERO= 0.000 0.000
SERIAL#: 848504 #1 = 7.523 7.523 25.08 25.03
RANGE: 1000 PSIG #2 = 15.046 15.046 50.16 50.09
DATE: 17 FEB 89 #3 = 22.570 22.570 75.24 75.18
SL#: N/A #4 = 30.091 30.091 100.31 100.30
READOUT= 24930 TEMP.DEG.F = 73
MODE= POS EXCITATION = 9.9968 V.DC
REF STD= 16856 SENSITIVITY = 3.001 MV/V
SHUNTS= 3 MV/V POT OUT = 0.3060 MV
INS.RES.>10K MEG OHMS CONVERSION FACTOR = 3.33362966

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0%	0.000	0.000	0.000	0.000	0.000	0.00	
20%	6.001	6.000	6.002	6.001	6.001	20.01	
40%	12.016	12.019	12.014	12.016	12.016	40.06	
60%	18.026	18.021	18.025	18.024	18.024	60.09	
80%	24.019	24.013	24.023	24.018	24.018	80.07	
100%	29.998	29.998	29.996	29.997	29.997	100.00	
80%	24.032	24.034	24.036	24.034	24.034	80.12	0.05
60%	18.044	18.042	18.039	18.042	18.042	60.14	0.05
40%	12.027	12.024	12.026	12.026	12.026	40.09	0.03
20%	6.005	6.009	6.008	6.007	6.007	20.03	0.02
0%	0.000	0.000	-0.002	-0.001	-0.001	0.00	

Y=A+BX+CX^2 A=-5.358E-03 B=.300932 C= -8.67E-06
RR= .999999733

TCC
16783
STD'S

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	848504 SERIAL #	17 FEB 89 DATE/APPROVAL	TCC 16962 STD'S
1000 PSIG RANGE	N/A SL # / MODE	9.9968 EXCITATION V.DC.	3.001 MV/V SENS./ MV/V SHUNT MOD.	

ELECTRICAL SIMULATION	LINEARITY	HYSTERESIS
#1 = 25.03	100% = 100.00	80% = 0.05
#2 = 50.09	80% = 80.07	60% = 0.05
#3 = 75.18	60% = 60.09	40% = 0.03
#4 = 100.30	40% = 40.06	20% = 0.02
	20% = 20.01	0% = 0.00

ORIGINAL PAGE IS
OF POOR QUALITY

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
MODEL#: 206 ZERO= 0.000 0.000
SERIAL#: 870222 #1 = 7.512 7.512 25.04 25.04
RANGE: 1000 PSIG #2 = 15.023 15.023 50.07 50.07
DATE: 17 FEB 89 #3 = 22.535 22.535 75.11 75.10
SL#: N/A #4 = 30.047 30.047 100.15 100.15
READOUT: 24412 TEMP. DEG.F = 73
MODE: POS EXCITATION = 10.0000 V.DC
REF. STD: 16854 SENSITIVITY = 3.000 MV/V
SHUNTS: 3 MV/V POT. OUT = 0.3450 MV
INS. RES. >10K MEG OHMS CONVERSION FACTOR = 3.33303707

LOAD % RUN 1 RUN 2 RUN 3 AVERAGE AVE-ZERO % F.S. HYSTERESIS

0%	0.000	0.000	0.000	0.000	0.00
20%	5.995	5.992	5.996	5.994	19.98
40%	11.998	11.995	11.997	11.997	39.99
60%	18.006	18.010	18.004	18.007	60.02
80%	24.015	24.012	24.010	24.012	80.03
100%	30.003	30.001	30.004	30.003	100.00
80%	24.021	24.018	24.025	24.021	80.06
60%	18.017	18.021	18.017	18.018	60.06
40%	12.014	12.010	12.012	12.012	40.04
20%	5.998	5.991	5.996	5.995	19.98
0%	0.000	-0.003	-0.002	-0.002	-0.01

Y=A+BX+CX^2 A=-3.81E-03 B=.30014 C= -3E-07
RR= .999999785

TCC
16783
STD'S

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER	206	870222	17 FEB 89
MANUFACTURER	MODEL #	SERIAL #	DATE/APPROVAL
1000 PSIG	N/A	POS	3.000
RANGE	SL # / MODE	EICITATION V.DC.	MV/V SENS./ MV/V SHUNT MOD.

TCC
16962

ELECTRICAL	LINEARITY	HYSERESIS
SIMULATION	100% = 100.00	80% = 0.03
#1 = 25.04	80% = 80.03	60% = 0.04
#2 = 50.07	60% = 60.02	40% = 0.05
#3 = 75.10	40% = 39.99	20% = 0.00
#4 = 100.13	20% = 19.98	0% = -0.01

ORIGINAL PAGE IS
OF POOR QUALITY

TRANSDUCER WORKSHEET I AP 28 A1

MFG.: TABER
MODEL #: 206
SERIAL #: 870222
RANGE: 1000 PSIG
DATE: 17 FEB 89
SL#: N/A
READOUT: 24412
MODE: POS
FREE STD: 16854
SHUNTS: 3 MV/V
INS. RES. >10K MEG OHMS

3 MV/V SHUNTS -ZERO %F.S. SH/LIN
ZERO= 0.000 0.000
#1 = 7.510 7.510 25.04 25.03
#2 = 15.021 15.021 50.07 50.07
#3 = 22.533 22.533 75.12 75.11
#4 = 30.044 30.044 100.15 100.15
TEMP. DEG.F = 73
EXCITATION = 10.0003 V.DC
SENSITIVITY = 3.0001 MV/V
POT OUT = 0.3440 MV
CONVERSION FACTOR = 3.33359261

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.001	0.000	0.000	0.000	0.00	
20% =	5.992	5.994	5.993	5.993	5.993	19.98	
40% =	12.000	12.006	12.000	12.002	12.002	40.01	
60% =	18.002	18.004	18.004	18.003	18.003	60.01	
80% =	24.003	24.000	24.008	24.004	24.003	80.02	
100% =	29.997	29.998	29.999	29.998	29.998	100.00	
80% =	24.014	24.014	24.013	24.014	24.013	80.05	0.03
60% =	18.017	18.023	18.019	18.020	18.019	60.07	0.06
40% =	12.009	12.006	12.009	12.008	12.008	40.03	0.02
20% =	5.994	5.997	5.991	5.994	5.994	19.98	0.00
0% =	-0.002	0.000	0.000	-0.001	-0.001	0.00	0.00

Y=A+BX+CX^2 A=-3.393E-03 B=.300148 C= -1.18E-06
RR= .999999894

TCC
16783
STD'S

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER 206 870222 17 FEB 89
MANUFACTURER MODEL # SERIAL # DATE/APPROVAL
1000 PSIG N/A POS 10.0003 3.000
RANGE SL # / MODE EXCITATION V.DC. MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL SIMULATION	LINEARITY	HYSERESIS
#1 = 25.03	100% = 100.00	80% = 0.03
#2 = 50.07	80% = 80.02	60% = 0.06
#3 = 75.11	60% = 60.01	40% = 0.02
#4 = 100.15	40% = 40.01	20% = 0.00
	20% = 19.98	0% = 0.00

MORTON THIOKOL, INC.

Space Operations

Appendix C
Calibration After Maximum Pressure Test

TRANSDUCER CALIBRATION WORKSHEET

ASCENDING

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
TABER	2210	882181	0 - 3000 #	1	7.526	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15.052	
BAROMETER	MEGOHMS TO GROUND	BATTERY	STANDARD	3	22.575	
LOADING TECH 6962 STD'S	RECORDING TECH. STD'S	COMPUTING TECH.	READ OUT	4	30.094	
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V	TENSION F.S.	CONVERSION FACTOR	6		
<input type="checkbox"/> RECEIVING INSPI.	SHUNT MODULE	MV/V				
APPLIED LOAD %				AVERAGE	% OF F.S.	LIN
Z OUT	INPUT	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5
0	0	0.000	-0.001	0.000	0.000	0.000
20	200	2.000	2.002	2.002	2.001	2.002
40	400	4.007	4.006	4.007	4.008	4.009
60	600	6.011	6.011	6.010	6.010	6.013
80	800	8.015	8.012	8.014	8.017	8.016
100	1000	10.016	10.017	10.017	10.018	10.018
80	1200	12.020	12.017	12.017	12.018	12.018
60	1400	14.017	14.015	14.016	14.016	14.017
40	1600	16.014	16.015	16.013	16.015	16.014
20	1800	18.011	18.008	17.992	18.009	18.009
0	2000	20.004	20.002	20.000	20.003	20.002
-20	2200	21.995	21.994	21.989	21.994	21.991
-40	2400	23.982	23.982	23.975	23.983	23.980
-60	2600	25.971	25.964	25.956	25.968	25.967
-80	2800	27.953	27.936	27.951	27.950	27.950
-100	3000	29.936	29.929	29.931	29.932	29.934
-80						
-60						
-40						
-20						
-0						
Z OUT						

FORM TC NO. 768

TRANSDUCER CALIBRATION WORKSHEET DESCENDING

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.				
TABER	2210	882181	0 - 3000 #	1						
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2						
BAROMETER	MEGOMHS TO GROUND	BATTERY	STANDARD	3						
<i>TCC LOADING TECH 62 STD'S</i>	RECORDING TECH. <i>(16952)</i> STDS	COMPUTING TECH.	READ OUT	4						
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	-5						
<input type="checkbox"/> SINGLE SHUNT	MV/V									
<input type="checkbox"/> RECEIVING INSPI.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR	6						
MV/V										
APPLIED LOAD %	INPUT	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5	AVERAGE	% OF F.S.	LIN	HYS
0	3000	29.935	29.930	29.932	29.933	29.933				
20	2800	27.958	27.953	27.954	27.955	27.954				
40	2600	25.976	25.969	25.972	25.975	25.974				
60	2400	23.992	23.984	23.986	23.990	23.990				
80	2200	22.006	22.000	22.000	22.004	22.004				
100	2000	20.009	19.999	20.011	20.014	20.013				
80	1800	18.021	18.018	18.019	18.022	18.022				
60	1600	16.029	16.027	16.025	16.029	16.028				
40	1400	14.028	14.025	14.028	14.032	14.031				
20	1200	12.032	12.029	12.034	12.033	12.033				
0	1000	10.026	10.027	10.030	10.031	10.032				
-20	800	8.029	8.026	8.028	8.029	8.029				
-40	600	6.027	6.020	6.026	6.024	6.024				
-60	400	4.016	4.015	4.016	4.017	4.018				
-80	200	2.008	2.007	2.006	2.009	2.009				
-100	0	0.001	0.000	0.000	0.000	0.000				
-80										
-60										
-40										
-20										
-0										
Z OUT										

TRANSDUCER CALIBRATION WORKSHEET

ASCENDING

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
TABER	2210	842268	0 - 3000 ±	1	7.586	
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2	15.097	
BAROMETER	MEGOMHS TO GROUND	BATTERY	STANDARD	3	22.627	
LOADING TECH. 6962 STD'S	RECORDING TECH. (16362)	COMPUTING TECH.	READ OUT	4	30.156	
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY MV/V	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	SHUNT MODULE MV/V	TENSION F.S.	CONVERSION FACTOR	6		
<input type="checkbox"/> RECEIVING INSPI.						
APPLIED LOAD %				AVERAGE	% OF F.S.	LIN
Z OUT	INPUT	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5
0	0	0.000	0.000	0.000	0.000	0.000
+20	200	2.016	2.014	2.013	2.012	2.013
+40	400	4.032	4.027	4.029	4.029	4.031
+60	600	6.049	6.046	6.045	6.045	6.047
+80	800	8.065	8.057	8.061	8.063	8.062
+100	1000	10.079	10.077	10.075	10.076	10.076
+80	1200	12.096	12.088	12.088	12.090	12.091
+60	1400	14.105	14.099	14.100	14.098	14.102
+40	1600	16.117	16.113	16.111	16.111	16.112
+20	1800	18.126	18.117	18.105	18.116	18.117
0	2000	20.130	20.121	20.117	20.121	20.123
-20	2200	22.134	22.127	22.123	22.125	22.124
-40	2400	24.134	24.126	24.123	24.126	24.124
-60	2600	26.134	26.123	26.125	26.124	26.123
-80	2800	28.128	28.103	28.121	28.118	28.118
-100	3000	30.122	30.111	30.110	30.111	30.111
-80						
-60						
-40						
-20						
-0						
Z OUT						

TRANSDUCER CALIBRATION WORKSHEET

DESCENDING

MANUFACTURER	MODEL	SERIAL NO.	RANGE	STEPS	SHUNTS	% OF F.S.
TABER	2210	842268	0 - 3000 \pm	1		
CHANNEL	CALIBRATION DATE	EXCITATION	LOADING INSTRUMENT	2		
	19 FEB 89	10.000 VDC	16856			
BAROMETER	MEGOHMS TO GROUND	BATTERY	STANDARD	3		
LOADING TECH 16962 STD'S	RECORDING TECH. 16962	COMPUTING TECH.	READ OUT	4		
<input type="checkbox"/> DOUBLE SHUNT	SENSITIVITY	COMPRESSION F.S.	AVERAGE F.S.	5		
<input type="checkbox"/> SINGLE SHUNT	MV/V					
<input type="checkbox"/> RECEIVING INSP.	SHUNT MODULE	TENSION F.S.	CONVERSION FACTOR	6		
MV/V						
APPLIED LOAD %				AVERAGE	% OF F.S.	LIN HYS
Z OUT	INPUT	RUN 1	RUN 2	RUN 3	RUN 4	RUN 5
0	3000	30.124	30.111	30.112	30.111	30.111
-20	2800	28.135	28.122	28.125	28.124	28.123
-40	2600	26.145	26.130	26.132	26.134	26.132
-60	2400	24.146	24.134	24.137	24.137	24.139
-80	2200	22.151	22.139	22.140	22.141	22.143
-100	2000	20.142	20.129	20.139	20.140	20.140
-80	1800	18.144	18.132	18.136	18.137	18.139
-60	1600	16.141	16.132	16.130	16.132	16.133
-40	1400	14.127	14.118	14.120	14.123	14.123
-20	1200	12.121	12.109	12.114	12.111	12.113
0	1000	10.101	10.095	10.099	10.099	10.100
-20	800	8.092	8.083	8.085	8.083	8.084
-40	600	6.078	6.063	6.070	6.067	6.065
-60	400	4.053	4.045	4.047	4.045	4.047
-80	200	2.023	2.023	2.025	2.024	2.024
-100	0	0.012	0.002	0.003	0.000	0.001
-80						
-60						
-40						
-20						
-0						
Z OUT						

MFG.: TABER 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
 MODEL#: 206 ZERO= 0.000 0.000 25.03 25.04
 SERIAL#: 870222 #1 = 7.512 7.512 25.03 25.04
 RANGE: 1000 PSIG #2 = 15.024 15.024 50.07 50.07
 DATE: 19 FEB 89 #3 = 22.537 22.537 75.11 75.10
 SL#: N/A #4 = 30.049 30.049 100.14 100.13
 READOUT: 24412 TEMP. DEG.F = 73
 MODE: POS EXCITATION = 10.0017 V.DC
 REF. STD: 16856 SENSITIVITY = 3.000 MV/V
 SHUNTS: 3 MV/V POT OUT = 0.3400 MV
 INS. RES. >10K MEG OHMS CONVERSION FACTOR = 3.33262978

LOAD	RUN X	RUN Y	RUN Z	AVERAGE	AVE-ZERO	% F.S.	HYSERESIS
0% =	0.000	0.000	0.000	0.000	0.000	0.00	
20% =	5.988	5.995	5.998	5.994	5.994	19.97	
40% =	12.002	11.999	12.002	12.001	12.001	39.99	
60% =	18.004	18.011	18.004	18.006	18.006	60.01	
80% =	24.012	24.010	24.019	24.014	24.014	80.03	
100% =	30.008	30.010	30.001	30.006	30.006	100.00	
80% =	24.022	24.024	24.029	24.025	24.025	80.07	0.04
60% =	18.028	18.029	18.018	18.025	18.025	60.07	0.06
40% =	12.010	12.017	12.007	12.011	12.011	40.03	0.04
20% =	5.998	5.996	5.999	5.998	5.998	19.99	0.02
0% =	-0.004	0.000	0.000	-0.001	-0.001	0.00	0.00

**Y=A+BX+CX^2 A=-3.727E-03 B=.30016 C= -2.3E-07
RR= .99999984**

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER	206	870222	19 FEB 89
MANUFACTURER	MODEL #	SERIAL #	DATE/APPROVAL
1000 PSIG	N/A	POS	10.0017
RANGE	SL # / MODE		EXCITATION V.DC.
			3.000
			3
			MV/V SENS./ MV/V SHUNT. MOD.

<u>ELECTRICAL</u>	<u>LINEARITY</u>	<u>HYSTERESIS</u>
SIMULATION	100% = 100.00	80% = 0.04
#1 = 25.04	80% = 80.03	60% = 0.06
#2 = 50.07	60% = 60.01	40% = 0.04
#3 = 75.10	40% = 39.99	20% = 0.02
#4 = 100.13	20% = 19.97	0% = 0.00

TRANSDUCER CALIBRATION REPORT

**ORIGINAL PAGE IS
OF POOR QUALITY**

MFG.: TABER
 MODEL#: 206
 SERIAL#: 870222
 RANGE: 1000 PSIG
 DATE: 19 FEB 89
 SL#: N/A
 READOUT: 24412
 MODE: POS
 REF. STD: 16856
 SHUNTS: 3 MV/V
 INS.RES.>10K MEG OHMS

3 MV/V SHUNTS -ZERO %F.S. SH/LIN
 ZERO= 0.000 0.000
 #1 = 7.512 7.512 25.04 25.03
 #2 = 15.025 15.025 50.08 50.06
 #3 = 22.537 22.537 75.11 75.10
 #4 = 30.050 30.050 100.15 100.14
 TEMP.DEG.F = 73
 EXCITATION = 10.0016 V.DC
 SENSITIVITY = 3.000 MV/V
 POT OUT = 0.3390 MV
 CONVERSION FACTOR = 3.33288895

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.000	0.001	0.000	0.000	0.00	
20% =	5.997	5.997	5.997	5.997	5.997	19.99	
40% =	11.998	11.999	12.008	12.002	12.001	40.00	
60% =	18.007	18.012	18.016	18.012	18.011	60.03	
80% =	24.007	24.016	24.016	24.013	24.013	80.03	
100% =	30.008	30.009	29.998	30.004	30.004	100.00	
80% =	24.037	24.028	24.032	24.032	24.032	80.10	0.07
60% =	18.030	18.028	18.024	18.027	18.027	60.08	0.05
40% =	12.012	12.007	12.020	12.013	12.013	40.04	0.04
20% =	6.003	5.999	6.006	6.003	6.002	20.01	0.02
0% =	0.000	-0.003	0.000	-0.001	-0.001	0.00	0.00

$$Y=A+BX+CX^2 \quad A=-3.62E-03 \quad B=.30029 \quad C= -1.79E-06$$

RR= .999999841

TCC
16962
STD'S

CALIBRATING TECHNICIAN'S STAMP

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	870222 SERIAL #	19 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	POS EXCITATION V.DC.	3.000 MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL SIMULATION	LINEARITY	HYSTERESIS
#1 = 25.03	100% = 100.00	80% = 0.07
#2 = 50.06	80% = 80.03	60% = 0.05
#3 = 75.10	60% = 60.03	40% = 0.04
#4 = 100.14	40% = 40.00	20% = 0.02
	20% = 19.99	0% = 0.00

TRANSDUCER CALIBRATION REPORT

ORIGINAL PAGE IS
OF POOR QUALITY

MFG.:	TABER	3 MV/V SHUNTS	-ZERO	%F.S.	SH/LIN
MODEL#:	206	ZERO = 0.000	0.000		
SERIAL#:	848504	#1 = 7.523	7.523	25.07	25.02
RANGE:	1000 PSIG	#2 = 15.049	15.049	50.16	50.07
DATE:	19 FEB 89	#3 = 22.574	22.574	75.23	75.17
SL#:	N/A	#4 = 30.096	30.096	100.30	100.29
READOUT:	24412	TEMP. DEG.F. = 73			
MODE:	POS	EXCITATION = 9.9980 V.DC			
REF. STD:	16856	SENSITIVITY = 3.001 MV/V			
SHUNTS:	3 MV/V	POT OUT = 0.3000 MV			
INS. RES. >10K MEG OHMS		CONVERSION FACTOR = 3.33281489			

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSERESIS
0% =	0.000	0.000	0.000	0.000	0.000	0.00	
20% =	6.005	6.006	6.003	6.005	6.005	20.01	
40% =	12.015	12.017	12.029	12.020	12.020	40.06	
60% =	18.027	18.032	18.038	18.032	18.032	60.10	
80% =	24.023	24.031	24.033	24.029	24.029	80.08	
100% =	30.006	30.008	30.000	30.005	30.005	100.00	
80% =	24.060	24.050	24.050	24.053	24.053	80.17	0.09
60% =	18.054	18.051	18.047	18.051	18.051	60.16	0.06
40% =	12.029	12.025	12.038	12.031	12.031	40.10	0.04
20% =	6.012	6.008	6.016	6.012	6.012	20.04	0.03
0% =	0.000	-0.004	0.000	-0.001	-0.001	0.00	0.00

**Y=A+BX+CX^2 A=-5.727E-03 B=.301141 C= -9.87E-06
RR= .999999658**

CALIBRATING TECHNICIAN'S STAMP



~~TRANSDUCER CALIBRATION REPORT~~

TABER	206	840504	19 FEB 89
MANUFACTURER	MODEL #	SERIAL #	DATE/APPROVAL
1000 PSIG	N/A	POS	3.001
RANGE	SL # / MODE	EXCITATION V.DC.	MV/V SENS./ MV/V SHUNT MOD.

ELECTRICAL SIMULATION	LINEARITY	HYSTERESIS
	100% = 100.00	80% = 0.09
#1 = 25.02	80% = 80.08	60% = 0.06
#2 = 50.07	60% = 60.10	40% = 0.04
#3 = 75.17	40% = 40.06	20% = 0.03
#4 = 100.29	20% = 20.01	0% = 0.00

**ORIGINAL PAGE IS
OF POOR QUALITY**

MFG.: TABER 3 MV/V SHUNTS -ZERO %F.S. SH/LIN
 MODEL#: 206 ZERO= 0.000 0.000
 SERIAL#: 870222 848504 #1 = 7.525 7.525 25.08 25.04
 RANGE: 1000 PSIG #2 = 15.050 15.050 50.15 50.09
 DATE: 19 FEB 89 #3 = 22.576 22.576 75.23 75.17
 SL#: N/A #4 = 30.098 30.098 100.30 100.28
 READOUT: 24412 TEMP.DEG.F = 73
 MODE: POS EXCITATION = 9.9981 V.DC
 REF. STD: 16856 SENSITIVITY = 3.001 MV/V
 SHUNTS: 3 MV/V POT OUT = 0.2990 MV
 INS.RES.>10K MEG OHMS CONVERSION FACTOR = 3.33237085

LOAD	RUN 1	RUN 2	RUN 3	AVERAGE	AVE-ZERO	% F.S.	HYSTERESIS
0% =	0.000	0.000	0.000	0.000	0.000	0.00	
20% =	6.001	6.001	6.006	6.003	6.003	20.00	
40% =	12.017	12.017	12.020	12.018	12.018	40.05	
60% =	18.024	18.034	18.027	18.028	18.028	60.08	
80% =	24.030	24.028	24.039	24.032	24.032	80.08	
100% =	30.008	30.013	30.005	30.009	30.009	100.00	
80% =	24.040	24.043	24.055	24.046	24.046	80.13	0.05
60% =	18.054	18.055	18.045	18.051	18.051	60.15	0.07
40% =	12.031	12.034	12.028	12.031	12.031	40.09	0.04
20% =	6.009	6.005	6.013	6.009	6.009	20.02	0.02
0% =	-0.002	-0.002	0.000	-0.001	-0.001	0.00	0.00

$$Y = A + BX + CX^2 \quad A = -5.727E-03 \quad B = .300993 \quad C = -7.91E-06$$

RR = .999999615

CALIBRATING TECHNICIAN'S STAMP

TCC
16962
STD'S

TRANSDUCER CALIBRATION REPORT

TABER MANUFACTURER	206 MODEL #	870222 SERIAL #	19 FEB 89 DATE/APPROVAL
1000 PSIG RANGE	N/A SL # / MODE	POS EXCITATION V.DC.	3.001 MV/V SENS./ MV/V SHUNT MOD.

TCC
16962
STD'S

ELECTRICAL SIMULATION	LINEARITY	HYSTERESIS
100% = 100.00		80% = 0.05
#1 = 25.04	80% = 80.08	60% = 0.07
#2 = 50.09	60% = 60.08	40% = 0.04
#3 = 75.17	40% = 40.05	20% = 0.02
#4 = 100.28	20% = 20.00	0% = 0.00

TRANSDUCER CALIBRATION REPORT

MORTON THIOKOL, INC.

Space Operations

DISTRIBUTION

<u>Recipient</u>	<u>No. of Copies</u>	<u>Mail Stop</u>
I. Black	1	L36
R. Jensen	1	L36
J. Griffen	1	L36
R. Clark	1	E13
C. Prokop	1	L36
D. Garecht	1	L36
J. Fonnesbeck	1	L23
R. Quick	1	L23
T. Morgan	1	M41
T. Suantengco	1	L10
V. Bastian	1	741A
R. Baird	1	561B
B. Bryner	1	561E
L. Stevens	1	561
K. Sanofsky	1	851B
R. Mikesell	1	811
F. Duersch	1	851B
M. Williams	1	L36
R. Lavery	1	L35
C. Johnson	1	L31
D. Cox	1	L30
B. Papasian	45	E05
Print Crib	5	282
Data Management	5	L23E

REVISION _____

DOC NO. TWR-19248
SEC PAGE VOL